



Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE: 3/27/2025	CLIENT/CLIENT ADDRESS MELA 9060 Zanzibar Ln N Maple Grove, MN 55311	SCHOOL/ADDRESS Minnesota Excellence In Learning Academy (MELA) 9060 Zanzibar Ln N Maple Grove, MN 55311
REPORT #: 25-03620		

SAMPLE INFORMATION

RECEIPT DATE/TIME: 3/20/2025 at 9:15	TEMP OF SAMPLE UPON RECEIPT: 12 °C	COLLECTED BY: <input type="checkbox"/> TCWC <input checked="" type="checkbox"/> CLIENT <input type="checkbox"/> Other
---	---------------------------------------	--

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	ACTION LEVEL*	RESULT
25-03620	Lead	South Side Hallway Drinking Fountain	3/19/2025	7:30	3/22/2025	15:04	SM3113B-93	5 µg/L	<2.00 µg/L
25-03621	Lead	Preschool A Classroom Sink	3/19/2025	7:35	3/22/2025	15:10	SM3113B-93	5 µg/L	<2.00 µg/L
25-03622	Lead	Kitchen Lower Level South Side Sink	3/19/2025	7:37	3/22/2025	15:16	SM3113B-93	5 µg/L	<2.00 µg/L
25-03623	Lead	Kitchen Lower Level Lunch Room Sink	3/19/2025	7:42	3/22/2025	15:22	SM3113B-93	5 µg/L	<2.00 µg/L

*The action level is determined by MN Statute 145.9273.

NOTES

APPROVED BY:

Frances Turner - Laboratory Director

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.